

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-0554:127

Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Johnson Controls, 507 E. Michigan St., Milwaukee, WI 53202-5211*
Contact: *James D. Kinney (414) 524-4358

DESIGN: Models FD-1310 (Type FOVBN) fire dampers and FS-1300 (Type TOVBE and TOVBP) fire/leakage dampers. Unit is a single and multiblade type construction. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:	<u>Models</u>	<u>Position</u>	<u>Single Section</u>		<u>Rated</u>		
			<u>Width</u>		<u>Height</u>		
			<u>Min.</u>	<u>Max.</u>	<u>Min.</u>	<u>Max.</u>	
	TOVBE, TOVBP V	15"	32"	8"	48"	1-1/2 Hr.	
	TOVBE, TOVBP H	15"	32"	8"	36"	1-1/2 Hr.	
	FOVBN	V	8"	32"	8"	48"	1-1/2 Hr.
	FOVBN	H	8"	32"	8"	36"	1-1/2 Hr.

These dampers are intended for use with Models DMPR-S60024S, DMPR-S60120S or DS-3153 fire damper operators.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For vertical installation only.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL: Listed as fire dampers for use in heating, ventilating and air conditioning duct systems passing through fire resistive walls, partitions or floors.

NOTE: Leakage rating not evaluated. Refer to CSFM Category 3230 for leakage rated dampers.

*Rev. 06-10-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 10, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager